



PIMPRI CHINCHWAD MUNICIPAL CORPORATION, PIMPRI-18
FIRE DEPARTMENT



File No. 0567

O.W.No:-Fire/023/ASME/WS/0567/2023

11/12/2023

FIRE SAFETY CERTIFICATE

Token No. 201321638023467

Token Date: 30.11.2023

Certified that the Audyogik Shikshan Mandal, building no. 3 at Plot No. 133 Part II of MIDC, Block 'C', Chinchwad, Pune 411019 comprised of Ground Floor, First Floor, Second Floor, Third Floor & Fourth Floor (constructed area 4310.90 sq. mtr and 18m High) occupied by ASM's Empros International School, Chinchwad have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 30.11.2023 in the presence of Dr. Vaishali Chavan C/o. ASM's Empros International School, MIDC, Block 'C', Chinchwad, Pune 411019 and that the building/premises is fit for occupancy upto classes From nursery to class XII With effect from 30.11.2023 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

- ✓ 1. The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
2. The fire extinguishers handling and operational training to be imparted to the teaching/ non-teaching/security staff of the school.
- ✓ 3. You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-'B' Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
4. You will keep all the Static Water Tanks full for any fire emergency.
5. Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- ✓ 6. You will keep all passages and corridors free from any obstructions and combustible material.
- ✓ 7. "No Smoking Boards" "Emergency Exit" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
8. You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
9. You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
10. This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
11. You are not permitted to construct the school building's remaining floors in the school working hours.
- ✓ 12. All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- ✓ 13. This Fire NOC is valid up to Dt. 29.11.2024 only and renewal of these NOC should be done every year before above-mentioned date with respect to full fill all mandatory conditions.
- ✓ 14. NOC issue as per the list enclosed fire related equipment's and mark constructed area as above mention.

0567
30.11.23
✓

(Signature)
11/12/2023

Fire Officer,
Pimpri Chinchwad Municipal Corporation,
Pimpri-18

✓
To,

Principal,
ASM's Empros International School, MIDC, Block 'C', Chinchwad, Pune 411019.