

Ref: (ASM (FF) NOC) No.EE©/A83686/of
2016 Office of the Executive Engineer,
MIDC, Civil Division , Chinchwad, Pune-19

DATE: 29.08.26

To,

Principal Dr. Vaishali Chavan C/o,
ASM's Empros International School,
MIDC , Block 'C, Chinchwad ,Pune 411019.

Appendix XII
FIRE SAFETY CERTIFICATE

Certified that the Audyogik Shikshan Mandal, building no. 3 at Plot No. 133 Part II of MIDC , Block 'C, Chinchwad ,Pune 411019 comprised of Ground Floor, First Floor, Second Floor, Third Floor & Fourth Floor (constructed area 5062.45 sq m and 18m Hight) occupied by **ASM's Empros International School, Chinchwad** have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24.08.2026 in the presence of Principal Dr. Vaishali Chavan C/o. ASM's Empros International School, MIDC , Block 'C, Chinchwad ,Pune 411019 and that the building/ premises is fit for occupancy up to classes from nursery to class XII With effect from 24.08.2026 for a period of one year 23.08.2027 in accordance with rule and subject to compliance of specific conditions as appended :

Conditions:

1. The entire Fire Protection system installed at the site should be maintained in excellent working condition for any fire emergency.
2. The Fire Extinguisher handling and Operational training to be imparted to the Teaching / Non-Teaching staff.
3. Testing, maintenance & refilling of all Fire Extinguishers / Fire Protection Systems should be carried out regularly.
4. Static water tanks should be kept full for any fire emergency.
5. Fire/Emergency Evacuation Mock Drill should be carried out in the school once every six months.
6. Passages and corridors should be kept free from obstructions and combustible material.
7. Emergency boards and contact details should always be displayed.
8. Fire protection systems should be easily accessible and maintained in good working condition.
9. This NOC is issued only from the fire safety point of view.
10. Construction during school working hours is not permitted.
11. All rules and regulations declared by PCMC or Govt. of Maharashtra shall be binding.
12. This Fire Certificate is valid up to 23.08.2027

AL
me

AD
29/8

pl 29/8
Fire Officer,
(EE) Office, MIDC, Chinchwad-19