



तळेगाव दाभाडे नगरपरिषद

तळेगाव दाभाडे, ता. मावल, जि. पुणे

दूरध्वनी क्र : १८००-२३३-२९३४

ई-मेल : talegaondabhadenrc@gmail.com

वेबसाईट : www.talegaondabhadenrc.org

WhatsApp क्र. : ९८९०६९६०८९



स्वातंत्र्याचा अमृत महोत्सव

Ref.EMP/Plot 401/233-B/11/26-27

Date: 25.08.2026


FIRE CERTIFICATE

Certified that the ASM's Empros International School, 401/1, Talegaon Dabhade, Tal: Maaval, Dist: Pune - 410506 comprised of Floors - Ground Floor, First Floor & Second Floor (constructed area 4685.55 sq. mtr and 12m Height) occupied by ASM's Empros International School, Talegaon Dabhade have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24.08.2026

Conditions:

1. The entire Fire Protection system installed at the site should be maintained in excellent working condition for any fire emergency.
2. The Fire Extinguisher handling and Operational training to be imparted to the Teaching / Non-Teaching staff.
3. Testing, maintenance & refilling of all Fire Extinguishers / Fire Protection Systems should be carried out regularly.
4. Static water tanks should be kept full for any fire emergency.
5. Fire/Emergency Evacuation Mock Drill should be carried out in the school once every six months.
6. Passages and corridors should be kept free from obstructions and combustible material.
7. Emergency boards and contact details should always be displayed.
8. Fire protection systems should be easily accessible and maintained in good working condition.
9. This NOC is issued only from the fire safety point of view.
10. Construction during school working hours is not permitted.
11. All rules and regulations declared by PCMC or Govt. of Maharashtra shall be binding.
12. This Fire Certificate is valid up to 23.08.2027




Fire Officer,
Fire Department,
Talegaon-(D) 410507