



PUNEMETROPOLIS

पुणे महानगर प्रदेश विकास प्राधिकरण, पुणे

Pune metropolitan Regional Development Authority, Pune

Office Address: Talegaon Fire Station, Floriculture Park, Talegaon MIDC, Talegaon MIDC, Maharashtra, 410507, Email: tfirepmrda@gmail.com, Tel: 02114-222449

R/No. ASM/Fire/corrected NOC/31251 /2024-25

Token No.654379

Date : 26.02.2024

(Corrected copy)

FIRE CERTIFICATE

Certified that the ASM's Empros International School, 401/1, 402/1, 403/1/B, Talegaon Dabhade, Tal: Maval, Dist : Pune – 410506 comprised of Floors - Ground Floor and First Floor (constructed area 4000 sq. mtr and 9m Height) occupied by ASM's Empros International School, Talegaon Dabhade have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 30.11.2023 in the presence of Mr. Shaikh Ishtiyaque Ahmed C/o, ASM's Empros International School, 401/1, 402/1, 403/1/B, Talegaon Dabhade, Tal: Maval, Dist : Pune – 410506 and that the building/ premises is fit for occupancy upto classes From nursery to class XII With effect from 21.02.2024 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-


1. The entire Fire Protection system installed at the site should be maintained in excellent working condition for any fire emergency.
2. The Fire Extinguisher handling and Operational training to be imparted to the Teaching / Non-Teaching staff.
3. You will carry out testing, maintenance & refilling of all Fire Extinguisher / Fire Protection Systems from competent person and necessary Form-B certificate regarding the maintenance & operational condition of the firefighting system to be submitted to the fire office as per the Section -3 (3) of the Fire ACT 2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
4. You will keep all the static water tanks full for any fire emergency.
5. Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
6. You will keep all passages and corridors free from any obstructions and combustible material
7. "No Smoking Board", "Emergency Exit", "Emergency Contact Number of Fire policy", "MSEB", "Ambulance" in Assembly Area shall be always displayed to avoid/ minimize fire / emergency situation / risks.
8. You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
9. This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes however necessary permission from the statutory authorities should be obtained.
10. You are not permitted to construct the school building's remaining floors in the school working hours.
11. All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
12. This Fire is valid up to 20.02.2025 only and renewal of these NOC should be before above-mentioned date with respect to full fill all mandatory conditions.
13. NOC issue as per the list enclosed fire related equipment's and mark constructed area as above mention.
14. NOC Corrected copy (Village name correction) issued against Re. No. 31245 Dated 22/02/2024, application

Note:

Principal, ASM's Empros International School Application correction in village name received on dated 23.02.2024.
Copy to Principal, ASM's Empros International School, 401/1, 402/1, 403/1/B, Talegaon Dabhade, Tal: Maval, Dist Pune- 410506.


MANAGER
Empros International School
Talegaon Dabhade




Fire Officer,
Fire Dept. (PMRDA),
Talegaon-(D) 410507


PRINCIPAL
A. S. Ms.
EMPROS INTERNATIONAL SCHOOL